

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:04 pm

PWS ID: UTAH11055 **Name:** CROSS HOLLOW HILLS SUBDIVISION
Legal Contact: CROSS HOLLOW HILLS SUBDIV **Rating:** Approved
 GEORGE R MASON **Rating Date:** 06/24/1996
Address: 1837 S HILLCREST DR **Activity Status:** Active
 CEDAR CITY, UT 84720
Phone Number: 435-867-8167
City Served (Area):
County: IRON COUNTY
System Type: Community **Last Inv Update:** 03/03/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 05/18/2010 **Total Dsgn Cap:**
Population: 350 **Surveyor:** JOHN GALLIS **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	MASON, GEORGE R	OPERATOR	435-590-8169	435-867-8167	georm@aol.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	133
			133 Total Svc Connections

Storage

Total Storage: 440,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST002	335 K TANK	Elevated	335,000 GAL	Steel		A	NO
ST001	105 K TANK	Ground	105,000 GAL	Steel		A	NO

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	CROSS HOLLOW HILLS PUMP STA	A		P			

Distribution System

Pump Type	Total Dyn Head		Pressure Adequate	Cross Connection	Auhority Statement
	ft H2O	P.S.I.			
			No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL NO 1	Active	WL		115 GPM	110 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	ABANDONED	Inactive	WL		140 GPM	100 GPM	Yes	GW	Other		
WS003	2008 REPLACEMENT WELL	Active	WL		123 GPM	175 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.